



**Consulting Engineers & Land Surveyors**

*1976 – 2022 • 46 YEARS OF EXCELLENCE*

January 4, 2022  
#03-73084

Township of North Fayette  
400 North Branch Road  
Oakdale, PA 15071

ATTN: Andrew Hartwell  
Community Development Director

RE: Fayette Farms Phase 10 FPRD  
Revised Tentative Planned Residential Development  
Review No. 1

Dear Mr. Hartwell:

We are requesting a waiver from the Township's Construction Standards (Section 512.1). The maximum depth permitted for a sanitary manhole is 20 feet.

Two manholes exceed this depth due to the topography of the ground and the sanitary sewer proposed to service Phase 14.

Very Truly Yours,  
**J.R. GALES & ASSOCIATES, INC.**

A handwritten signature in black ink that reads "John Robert Gales". The signature is written in a cursive, flowing style.

John Robert Gales, P.E., P.L.S.  
JRG:ddb